

	Water Sample Test Comparison / Scott County Well # 3			
Nutrients	CWA			
		May. 2020	Oct. 2020	May. 2021
PH		6	6.1	6.6
NH4N ppm	2.00 ppm			
NH3N ppm		0.14	0.92	0.94
NO3N ppm	10.00ppm	2.87	6.81	5
Phosphrous	1.00ppm	0.01	0.01	
Potassium		1.6	1.8	10
Calcium		14.8	18.3	19.4
Magnesium		6.9	11	4.5
SO4-S		12.9	6.1	6.6
Arsenic-Ar		<.001	<0.0010	

CWA = Clean Water Act Threshold